



Ph. - (03228) 239627 // 254369

VIVEKJYOTI COLLEGE

(A Unit of Vivekananda Education Trust)

B.Ed & D.El.Ed. Regular Composite Course

Estd. - 2007 :: Recog. by :- NCTE

Affiliated to - BABA SAHEB AMBEDKAR EDUCATION UNIVERSITY

(Erstwhile : The West Bengal University Of Teachers' Training, Education Planning And Administration) & WBBPE

P.O. - Uttar Mechagram * Panskura * Dist. - Purba Medinipur * Pin - 721139 (W.B.)

Ref. No. VJC/TIC/Reg./BSAEU/Affiliation/2023/807

Date. 10.10.23

To
The Hon'ble Registrar,
Baba Saheb Ambedkar Education University,
25/2 & 25/3, Ballygunge Circular Road,
Kolkata-700019



Sub: Request for affiliation for B.Ed. Course in favour of Vivek Jyoti College, session-2023-2025 and submission of 'Fire Safety Certificate'.

College Code-17012

Respected Sir,

With honour I beg your kind permission for affiliation of our college for the session 2023-25. For that I have already submitted all required documents vide ref. No. VJC/TIC/Reg./BSAEU/Affiliation/2023/805 Dated 19.09.23 as stated by you and now I am submitting the Fire Safety Certificate after its renewal.

Therefore I request your honour to be so kind to issue the affiliation certificate and request to open the portal for online form fill up for students' admission as early as possible.

Thanking You

Yours faithfully,

Encloser:

1. Renewal of Fire Safety Certificate
2. Receiving Copy of Previously Submitted Documents,
On 19.09.2023

Manas Mr. Sahu.

Manas Kumar Sahu
(Teacher-in-Charge)
Teacher-in-Charge
Vivek Jyoti College (Under V.E.T.)
P.O. - Uttar Mechagram, Panskura,
Dist. - Purba Medinipur, W.B.



Ph.- (03228) 239627 // 254369

VIVEKJYOTI COLLEGE

(A Unit of Vivekananda Education Trust)

B.Ed & D.El.Ed. Regular Composite Course

Estd.- 2007 :: Recog. by :- NCTE



Affiliated to - BABA SAHEB AMBEDKAR EDUCATION UNIVERSITY

(Erstwhile : The West Bengal University Of Teachers' Training, Education Planning And Administration) & WBBPE

P.O. - Uttar Mechagram * Panskura * Dist. - Purba Medinipur * Pin - 721139 (W.B.)

Ref. No. VJC/TIC/Reg./BSAEU/Affiliation/2023/805

To,
The Hon'ble Registrar,
Baba Saheb Ambedkar Education University,
25/2 & 25/3, Ballygunge Circular Road,
Kolkata-700019



Respected Sir,

Sub: Request for Affiliation considering my papers.

With honour and humble submission I beg to inform you that:

1. as per your direction we have verified our ERC copy from your end on 12.06.2023 and that copy is submitted to you.

2. I am submitting the DBT statement in favour of our staff members. For your kind information our Physical Science teacher has applied for leave without pay for his personal hazards. He repeatedly requested by phone that after overcoming his problems he will join our college again. Considering this condition we have already engaged Mr. Sital Chandra Maity to take those classes.

3. Regarding the fire safety certificate I would like to inform you that we got our Fire Safety certificate initially on 14.10.2015 and Fire Safety certificate has been renewed time and again and the last certificate was valid up to February 2023.

Now I have submitted the application for renewal on 10.04.2023 and 06.09.2023 and at present on 11.09.2023. The inspection is also completed. So just after getting the certificate I will submit to you very soon.

Thanking You

Yours faithfully,

Encloser:

1. Verified ERC Copy
2. DBT of Last Three Months
3. Application for Fire Safety
4. Last Fire safety certificate

Manas K. Sahu 19.9.23

Manas Kumar Sahu
(Teacher-in-Charge)

Teacher-in-Charge
Vivek Jyoti College (Under V.E.T.)
P.O. - Uttar Mechagram, Panskura,
Dist. - Purba Medinipur, W.B.



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:IND/WB/FES/20192020/81384

Date: 10-10-2023

From:

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: VIVEKJYOTI COLLEGE

PO - UTTAR MECHAGRAM, PANSKURA, DIST - PURBA MEDINIPUR, PIN - 721139

Sub: Renewal Fire Safety Certificate of an existing educational institution comprising two nos. block i.e. BLOCK- A :- G+IV Storied building and BLOCK- B:- G+II storied building in the name & style of " VIVEKJYOTI COLLEGE " under group of educational occupancy at the premises of PO - UTTAR MECHAGRAM, PANSKURA, DIST - PURBA MEDINIPUR, PIN - 721139, JL NO - 74, DAG NO - 1006, KHATIAN NO – 494,

This is in reference to your application no. 0125191231400197 dated 10-09-2023 regarding the Renewal Fire Safety Certificate of an existing educational institution comprising two nos. block i.e. BLOCK- A :- G+IV Storied building and BLOCK- B:- G+II storied building in the name & style of " VIVEKJYOTI COLLEGE " under group of educational occupancy at the premises of PO - UTTAR MECHAGRAM, PANSKURA, DIST - PURBA MEDINIPUR, PIN - 721139, JL NO - 74, DAG NO - 1006, KHATIAN NO – 494,

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Conditional Renewal fire safety Certificate allow, subject to,-

1. As exceed the floor area (over 1000 sq.mtrs.), provide another Down comer at another stair case.
2. Provide Stand by pump as same capacities of main Pump and should be driven by auto mode.

Comply the above conditions with in Three months from the date of issuing of this Certificate and inform to this end by written with photograph positively to regularization the Certificate.

However, to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be

incorporated / maintained.

1.All the Fire Safety Recommendation which was issued by this office vide memo no.- WBFES/1091/16/Purba Medinipur-EB/111/16(111/16) DT.- 09.02.2016, to be followed strictly at all time.

2.Another one fire pump with same capacity of main fire pump preferably diesel driven type shall have to be installed as an alternative.

3.Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking will be allowed on the driveway.

4.The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.

5.To eliminate risk of fire hazards, Good House Keeping both for inside and outside of the building shall be strictly maintained.

6.Electrical wiring of the whole building shall have to be carefully checked for any wire and tear in them, Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March in every year.

7.A fire control room including a CCTV system will have to be maintained, which observe all floor of the building.

8.The notice of fire fighting and Evacuation from the shall be prepared and displayed at all venerable of the building.

9.The employees and security staff, shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of fire and testing.

10.Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

11.Electrical installation room shall be protected with automatic CO2 or D.C.P. Fire extinguishers confirming I.S. Specification.

12.Unauthorized cooking arrangement in any floor of the hotel building except kitchen by using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

13.Arrangement shall have to be made for regular checking, testing and maintenance of all fire fighting installation in the building to keep them in perfectly good working condition at all the items.


14.Periodical flashing of water in the Hose reel hose pipe line shall made to maintain the efficiency working performance of above mention system.

15.The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

16.This certificate valid for 03 year from the date of issuance of this certificate.

A renewal certificate is to be obtained in every three year from the Director General, West Bengal Fire & Emergency Services for performance of all the life & fire safety arrangements and installations of the building.

Signature valid


Digitally Signed:
Name: Barn Kumar Choudhury
Date: 10-Oct-2023 10:38
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services